A city skyline at sunset or dusk. The sky is filled with soft, orange and yellow light, transitioning into a darker blue. Several high-rise buildings are visible, some with lights on. A construction crane is positioned in the middle ground, with its lights on. A large red diagonal graphic cuts across the lower half of the image, creating a dark triangular area at the bottom left.

# NUCLEUS COMMISSIONING GUIDE

AimLite

# COMMISSIONING


## REQUIREMENT AND PREPARATION

Here are some recommendations to facilitate the commissioning:


- When powered without being commissioned, all devices will be normally ON. For this reason, it is possible to perform a visual inspection of all units to validate that they are ON. If some units are not ON, it will be necessary to validate if they are properly installed or have any defect.
- Validate if the system is currently setup on an active network with WI-FI access.
  - If yes (preferable), you will be able to use this network to access the system and will allow more mobility during the commissioning process and will make the final validation easier. Any device with a WI-FI access and browser can be used, but a computer is recommended. (Network credential will be required)
  - If not, you will require a computer with RJ45 cable to connect directly on the system. This will restrict your mobility during the commissioning and final validation. This is not recommended for large-scale project.

## WEB USER INTERFACE CONNEXION WITH IP ADDRESS

- Either connect to the system network or connect the RJ45 cable between the system and computer.
- To log in the SU Web user interface, you first need to find the IP address of your system by using the HMI navigation menu. Use the **[OK]** button to access the main menu and then navigate to network settings using **[← ↑]** or **[↓ →]** button and press **[OK]** button. At this point, you can note the current IP address indicated by the system. (Please refer to **Figure 1**)



- You can then use your computer web browser to input the IP address in the browser address bar. (See **Figure 2**) Note that when you input an IP address in the address bar of your browser, you must remove the unnecessary 0 of each number separated by a dot. E.g. 192.168.000.089 → 192.168.0.89



- You have reached the SU web user interface; access the login screen by using the left side menu [See **Figure 3**]. For a new system, use the following for your first login:
  - User: Admin
  - PW: Admin

**Figure 3**

- For the first time logging in, you are asked to change the Admin password to a new password [4-12 characters necessary].

## ACCOUNTS CREATION AND MANAGEMENT

- To create and setup all required user accounts go in the **User administration tab** by using the navigation menu on the left side.
- When in the **User administration tab**, you can scroll down to the **new user** section [see **Figure 4**], you can simply input the name and password of a user you wish to create and click on "Add user" to create the new account. Note that 4-12 characters are necessary for both password and user name.

**Figure 4**

- Once you have created all the required accounts, then you can use the user rights section [see **Figure 5**] to control the rights of each user by checking or unchecking the options and clicking on submit when your selection is complete. **Note:** The user right are directly align with the tabs the user will have access to.

User	Device status	Device functions	General settings	Network settings	User administration
\$*Hersteller	<input checked="" type="checkbox"/>				
\$+Partner	<input checked="" type="checkbox"/>				
Admin	<input checked="" type="checkbox"/>				
1mfmercier	<input type="checkbox"/>				

**Figure 5**

## SETUP MAIL SERVER AND NOTIFICATIONS

- Setup your Mail server and Mail server authentication in the **Network settings** tab.
- In the **Mail server** section (see **Figure 6**), you can input your mail server information. All users accounts email address must be on the same mail server.

Mail server:

Mail server address:

SMTP port:

Return e-mail address:

Figure 6

- If your mail server requires an authentication, then you can input it in the **Mail server authentication** section (see **Figure 7**).

Mail server authentication (optional depending on mail server):

User name:

Password:

Figure 7

- The **E-mail settings tab** allow you to associate each account with an email address and chose witch event trigger an email for each account. To add an email address to an account you have click on the pen icon next to the account you want to add the email address in the E-mail address section (see **Figure 8**). From the newly open page you can input the email address and click on submit to apply the change. To select the event that trigger an email for each account, you can check or uncheck the event in E-mail events section (see **Figure 8**) and click on submit to apply the changes.

E-mail address:

\$\*Hersteller:  

\$+Partner:  

Admin:  

E-mail events:

	\$*Hersteller	\$+Partner	Admin
Operational	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Not operational	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Maintenance due	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Charging failure	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Circuit failure	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Luminaire failure	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Result FT	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="button" value="Submit"/>	<input type="button" value="Submit"/>	<input type="button" value="Submit"/>

Figure 8


## DEVICE SETTINGS

Fill in and adjust all settings described in this section under the **Device settings** tab.

- In the general setting, adjust the following settings:
  - **Device name** – The name of the device (20 characters max)
  - **Owner** – Name of the company or building (20 characters max)
  - **Location** – Location of the device (20 characters max)
  - **Delay on mains return for non-maintained light** – This setting is design for use in industrial and commercial applications that feature HID lights throughout the facility or building. HID lights, such as Metal Halide, Mercury Vapor, or High Pressure Sodium, have a “warm-up” time when turned on, meaning they do not reach their full light power, or luminosity, for set amount of time. This setting can be used to fix a minimum amount of time after a power failure before shutting down the emergency lighting. (0-20min)
  - **Duration time** – This setting define the emergency lighting maximum duration. Should be optimize based on your emergency lighting maximum capacity and in respect to the National building code. (30min to 8hrs)

Click on **Submit** when your settings are complete.

- In the system time section (see **Figure 9**) of the device settings, adjust the time and date of the system. Input the time and date and then click on **Submit**.



The screenshot shows the 'System time' configuration interface. It includes a 'Date' field with input boxes for day (26), month (06), and year (2019), with the label 'day.month.year' below. To the right is a 'Time' field with input boxes for hour (09) and minute (16), with the label 'hour:minute' below. A 'Submit' button is located to the right of the time field. Below the date and time fields is a checked checkbox labeled 'auto daylight saving time'.

**Figure 9**

- In the language section (see **Figure 10**) of the device settings, adjust the language of the system if necessary. Choose your language preference and then click on **Submit**.



The screenshot shows the 'Language' configuration interface. It features three radio button options: 'English' (which is selected), 'Francais', and 'Deutsch'. A 'Submit' button is positioned to the right of the language options.

**Figure 10**

- Function test section (see **Figure 11**) allows you to set the time at which the system will automatically test the operational status of the system. Input your preferred time and click on **Submit**.



The screenshot shows the 'Function test' configuration interface. It includes a 'Weekday of the function test' field with a dropdown menu currently set to 'Daily'. Below it is a 'Time of FT:' field with input boxes for hour (06) and minute (30), with the label 'hour:minute' below. A 'Submit' button is located to the right of the time field.

**Figure 11**

- Duration test section (see **Figure 12**) allows to set time for the monthly, intermediate and annual test. Set the option as preferred and click on **Submit**. **Note:** the annual test duration is required to be at least the system duration time.

**Duration test:**

Start (total test):  .  .   :

Keep day of the week:

Next execution: Su, 07.08.2022

**Monthly quick check:**

Test duration:  min

Repeat test after 24 h:

**Intermediate test:**

Test duration:  min

Repeat test after 24 h:

Frequent basis:  ▼

**Annually total test:**

Test duration:  min

Repeat test after 24 h:

Turn on speakers during Duration Test:

**Figure 12**

## CIRCUIT SETTINGS

Fill in and adjust all settings describe below in the **Circuit settings** tab.

- Circuit selection section (See **Figure 16**) allows you to select a specific circuit and assign it a name. To do so, simply select the circuit number you want to modify and click on load. Then, you can input the desired circuit name and click on **Submit**. **Note:** To work on any of the circuit, you need to first load the circuit in this section.

Circuit 1:  ▼

---

Circuit name:   

**Figure 13**

- When you first setup the system, it will not automatically recognise the devices on the circuit. You will have to select **Activate address mode** (see **Figure 14**). Note that this setting will stay active even when you switch between circuits. Then select **Search luminaires**.

**Functions for addressing:**

**Figure 14**

- Then you will get the following screen (see **Figure 15**) with the amount of units the system found for this circuit. Make sure the amount display matches the amount link to this circuit. You can then click on the **Auto address mode** and the system will add the units in the Luminaire in the circuit X section.

Luminaire search in circuit 1:

---

**Result:**

New luminaires:	4
Total found luminaires:	4
Luminaires without feedback:	0

Auto address mode

Manual address mode

Cancel

**Figure 15**

- Luminaires in the circuit X section (see **Figure 17**) allows you to modify a number of settings for each device on the currently selected circuit. When you first setup the system you will first need to locate and name each units. To do so, click on the pen icon next to one of the entry (see **Figure 17**). From the next screen (see **Figure 16**) you can select **Luminaire: start blinking**, this will make the selected unit blink and allow you to locate it. Note that you can also use a mobile device for this step, as long as you are on the same network and have access to a browser. Once located you can name the unit and modify the setting you need to change. Then, clicks on submit and then **Back to the circuit overview**. Proceed like this for all units on the circuit.

Luminaires in the circuit 1:

Addr.	Type	ID	Name	ML NM	Switch on when										dim value	Status		
					Input 1 INV	Conj.	Input 2 INV	Inp. 3 INV	Inp. 4 INV	Timer INV	Other							
1		03e52f	-	<input checked="" type="radio"/>	-	OR	-	-	-	-	-	-	-	-	100 %	<input checked="" type="checkbox"/>		

**Figure 16**

Change luminaire data to circuit 1:

Addr.	Type	ID	Name	ML NM	Blink
1		03e52f	-	<input checked="" type="radio"/>	

Switch on when						dim value
Input 1 INV	Conjunction	Input 2 INV	Input 3 INV	Input 4 INV	Timer INV	
-	OR	-	-	-	-	100 %

Submit

Luminaire: start blinking

...LCU-String

Back to the circuit overview

**Figure 17**

Once you have given a name to the each luminaire, there are a number of other settings you can configure from this section (see **Figure 18**):

- **ML/NM** – Respectively Maintained Light (Normally ON) and Non-Maintained Light (Normally OFF)
- **Input x** – Can be used to set a condition to turn on or off based on a specific input.
- **Timer** – Select if you want a Normally Off fixture to turn on base on the timer you set in Device settings.
- **Dim** – Can set a Dim value, this setting does not affect fixture in emergency mode. The value in emergency mode is always 100%.
- **INV** – If selected it will reverse the current setting.
- **Trash can icon:** Select to delete a specific luminaire.

Click on **Submit** when your settings are complete.

Luminaires in the circuit 1:

Addr.	Type	ID	Name	ML NM		Switch on when										dim value	Status			
						Input 1	INV	Conj.	Input 2	INV	Inp. 3	INV	Inp. 4	INV	Timer INV					Other
1		03e52f	-RM plastic	<input checked="" type="radio"/>	<input type="radio"/>	-	<input type="checkbox"/>	OR	-	<input type="checkbox"/>	-	<input type="checkbox"/>	-	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	100 %	<input checked="" type="checkbox"/>		
2		03e550	-RM rainstorm	<input checked="" type="radio"/>	<input type="radio"/>	-	<input type="checkbox"/>	OR	-	<input type="checkbox"/>	-	<input type="checkbox"/>	-	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	100 %	<input checked="" type="checkbox"/>		
3		03e55d	-RM Extruded	<input checked="" type="radio"/>	<input type="radio"/>	-	<input type="checkbox"/>	OR	-	<input type="checkbox"/>	-	<input type="checkbox"/>	-	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	100 %	<input checked="" type="checkbox"/>		
4		03e569	-RM Steel	<input checked="" type="radio"/>	<input type="radio"/>	-	<input type="checkbox"/>	OR	-	<input type="checkbox"/>	-	<input type="checkbox"/>	-	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	100 %	<input checked="" type="checkbox"/>		
5																				
6																				
7																				
8																				
9																				
10																				
11																				
12																				
13																				
14																				
15																				
16																				
17																				
18																				
19																				
20																				

Submit Delete all luminaires

**Figure 18**

- Repeat the step above from the beginning for each circuit. Note that you do not need to activate address mode in step B once again for the following circuit unless you deactivated it.
- When all circuit setups are completed, verify that all units are working as intended. You can use the blink feature to validate each device. If the system is on a WI-FI network, it is preferable to use a mobile device for the final verification.
- Deactivate the address mode.

# NOTES

# NOTES

# NOTES



# AimLite

2233 rue de l'Aviation,  
Dorval QC  
H9P2X6, CA

T 514 227-1288  
TF 1 866 348-2374  
f @ aimlite.com

2025-12-16